



# AGA CERTIFIED PRODUCT

Certificate Holder: **BONOMI INDUSTRIES SRL**

ABN/ACN No. (if applicable): N/A

Manufacturer: **BONOMI INDUSTRIES SRL**

Agent (if applicable): N/A

Type of Component: **MANUAL BALL VALVE (TYPE 1)**  
**Temperature rating: 0 – 60°C**

Model No. & Description: **RUB**  
*(Refer [www.aga.asn.au](http://www.aga.asn.au) for more details)*  
**S84 & S84GW – [F/F & M/F]**  
**NB 1/4", 5/8", 1/2", 3/4", 1", 1 1/2", 2"**  
**(8, 10, 15, 20, 25, 32, 40, 50mm)**  
**MWP 2100kPa**  
**S24 – [F/F]**  
**NB 1/2", 3/4", 1", 1 1/4", 1 1/2", 2"**  
**(15, 20, 25, 32, 40, 50mm)**  
**MWP 2100kPa**  
**S84 - [F/F & M/F]**  
**NB 2 1/2", 3" & 4"**  
**(65, 80, 100mm)**  
**MWP 1500kPa**

*Note: Various thread forms available in accordance to AS ISO 7.1*


Relevant Standard(s): **AS 4617 – 2004 (Including Amendment 1)**

This is to certify that the particular **COMPONENT** specifically described herein and supplied to The Australian Gas Association (hereafter called the AGA) by the Certificate Holder named above has been subject to "type-testing" and assessed by the AGA to comply with the requirements of the AGA's Product Certification Scheme for Type Tested Gas Products.

**This Certificate is issued on the express conditions that:**

- (i) The Certificate Holder undertakes to comply with the Rules Governing The AGA's Product Certification Scheme (hereafter called the Rules Governing);
- (ii) This Certificate remains the property of the AGA; and
- (iii) The AGA reserves the right to cancel this Certificate in accordance with the Rules Governing, and in such an event the Certificate Holder undertakes to surrender the Certificate to the AGA upon request.



  
**Client Manager**

  
**Certificate Authorised**

Certificate first issued: **16 March 1995**

Certificate No: **5244**

This copy valid from: **9 July 2019**

Refer specification issue: **08**

# Directory Certificate Entry

## Components

### Manual Shut-Off Valves

#### Type 1 - Isolating Valves

Bonomi Industries Srl

(Via Padana Superiore 27/29 - Frazione Ciliverghe, 25080 Mazzano (BS), ITALY Ph: +39 030 212 441)

Relevant Standard/s:

AS 4617 | 2004 Amdt 1 | Manual Shut-Off Gas Valves | 9/03/2011

#### RUB

5244

3.95

#### S84 & S24 Type 1 Manual Shut-off Valves

kPa Rating

#### S84 & S84GW - [F/F & M/F]

NB 1/4", 5/8", 1/2", 3/4", 1", 1 1/4", 1 1/2" and 2"  
(8mm, 10mm, 15mm, 20mm, 25mm, 32mm, 40mm, 50mm)

2100

#### S24 - [F/F]

NB 1/2", 3/4", 1", 1 1/4", 1 1/2", 2"  
(15mm, 20mm, 25mm, 32mm, 40mm, 50mm)

2100

#### S84 - [F/F & M/F]

NB 2 1/2", 3", 4"  
(65mm, 80mm, 100mm)

1500

Note: Various thread forms available in accordance to AS ISO 7.1

Temperature Rating: 0 - 60°C

Monday, 15 July 2019