



Certificate of Compliance

This certificate is issued for the following:

Quick Opening Valves
(see attached configuration table)

Prepared for:

Bonomi Industries srl (FKA Rubinetterie Utensilerie Bonomi srl)
Via Padana Superiore 29
Mazzano, Brescia 25080
Italy

FM Approvals Class: 1140 (October 1998)

Approval Identification: 0Z1A9.AH
Superseded by: RR220645

Date Approved: September 6, 1996
Date Approved: October 29, 2019

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

A handwritten signature in black ink that reads 'David B. Fuller'.

David B. Fuller
VP, Manager of Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062 USA



Member of the FM Global Group



Certificate of Compliance

Models S.84, S.92, S.95

<i>Product Designation</i>	<i>Description</i>	<i>Nominal Pipe Size in.</i>	<i>Pressure Rating psi (kPa)</i>	<i>Remarks</i>
S.84	Ball Valve	¼, 3/8, ½, ¾, 1, 1¼, 1½, 2	400 (2760)	d, e
S.84 GW	Ball Valve	¼, 3/8, ½, ¾, 1, 1¼, 1½, 2	400 (2760)	d, e, f, g
S.92	Ball Valve	¼, 3/8, ½, ¾, 1, 1¼, 1½, 2	400 (2760)	a, b
S.95	Ball Valve	¼, 3/8, ½, ¾, 1, 1¼, 1½, 2	400 (2760)	a, c

Remarks:

- a) Brass and chrome-plated finishes
- b) Available with female NPT or female x male NPT end connection
- c) Available with female NPT end connection
- d) Nickel plated finish
- e) Available with ISO 7/1 threads
- f) No internal plating
- g) Rinse hole in the valve ball



Member of the FM Global Group