



GAS.BE – ARGB – KVBG

The ARGB-KVBG laboratory certifies the conformity with the Belgian requirements for gas valves with MOP ≤ 5 bar for use outside of the buildings and MOP ≤ 100 mbar inside the buildings

Certificate number: C-20-3804-A

Date of issue: 15-07-2020

Fabricant:
Manufacturer: ***Bonomi Industries S.r.L.***
Fabrikant: Via Padana Superiore 29, IT-25080 Mazzano (BS) Italy.

Valve Type:
Valve Model: S84 (1/4" => 2")
Kraan Type:

Exigences belges:
Belgian Requirements: EN 331,
NBN D51-003 and NBN D51-006
Belgische eisen: MOP 5 bar only for outside building gas installations
MOP 100 mbar for inside the buildings

DVGW report 17/198/4312/272 from 2018/01/19
GAS.BE reports 2020/0051 and 2020/0052

Laboratory Manager

Olivier THIBAUT