



SWEDISH TYPE APPROVAL 0175

WITH DECISION ON PRODUCTION CONTROL

KEYWORD: Domestic Water
Ball valves for tapwater installations

BBR 6:62

Holder: Bonomi Industries S.r.l.

Via Padana Superiore, 27/29 Fraz.Ciliverghe 25080 Mazzano (BS) Italy

Tel: +39-030 212441

Fax.: +39-030 2629498

Email: quaresminie@rubvalves.com

Web: www.rubvalves.com

Product name: RUB Ball Valve, type s.21

Hot forged ball-valve of dezincification resistant brass Ball valve with solder connections and extended spindle. Approved sizes ø 10 – ø 54 mm

The ball-valve shall, to meet the requirements, be mounted according to the holder's instructions.

Intended use

Stop-valve for hot and cold domestic water

Approval

Products made and installed according to related documents are approved with respect to the following sections of the Swedish Building Regulations (BBR):

Building products with assessed properties	1:4
Tap water installations (1 st and 2 nd paragraph)	6:62*
Design (4 th and 2 nd paragraph)	6:625*

*The product fullfils requirements in BFS 2014:3

For the intended use the products meet the following requirements of PBL, regulations governing the technical properties of materials, products etc. used in construction works Chapter 8 Section 4 about the technical characteristics of buildings and constructions.

1. Bearing capacity, consistency and durability
3. Protection in terms of hygiene, health and environment

Appendix 1: Associated documents	19-01-2019
Appendix 2: Product marking	19-01-2019
Appendix 3: Control	19-01-2019
Appendix 4: Basis for approval	19-01-2019

CERTIFICATE

Kiwa Sverige AB
Campus Gräsvik 1
SE-371 75 Karlskrona

Tel +46 (0)455-30 56 00
Fax +46 (0)455-104 36
se.bygg@kiwa.com
www.kiwa.se



Date of decision: 19-01-2019

Ref. no: 768/18

Valid until: 18-01-2024

Previous ref. no: 794/13

Kiwa Sverige AB

Magnus Jerlmark
Technical manager

Johnny Ostfeldt
Project leader